



Brisbane City Council

Our Ref:

9 July 2001

The Manager  
Everhard Industries Pty Ltd  
PO Box 543  
**VIRGINIA BC Q 4014**

ATTENTION: Craig Robins

Dear Craig

Further to your letter of 19 March 2001, we acknowledge receipt of your request to approve the use of RibStruct pipe for stormwater drainage.

RibStruct is approved for use as stormwater drainage pipe for diameters up to and including 630mm. This approval is valid for a period of 12 months from the above date and subject to satisfactory performance of the product. Video inspection of lines constructed will be required at this time to ensure adequate performance of the product.

If you have any further queries please contact either myself or Michael Steer of this office.

Yours sincerely

Michael Steer  
Senior Asset Officer Roads & Drainage  
**Infrastructure Management**  
**BRISBANE CITY COUNCIL**

**Infrastructure Management**  
Strategic Infrastructure Management  
Urban Management Division  
BAC Floor 4  
69 Ann Street  
Brisbane Qld 4001

Telephone 07 340 39048  
Facsimile 07 340 39087  
E-mail: saord2@brisbane.qld.gov.au