



HERVEY BAY
CITY COUNCIL

Enquiries: Neville Lavey
Phone: (07) 41 259 740
Your Reference:
Our Reference:

22 April 2002

PO Box 5045
Torquay
Qld 4655

Mr Dan Mulhern
Technical Account Manager
Everhard Industries
PO Box 543
Virginia BC QLD 4014

Dear Sir

RIBSTRUCT – PRODUCT APPROVAL

I refer to your letter of 21st May 2001 and apologize for the delay in this response.

I advise that Council cannot approve RibStruct polypropylene pipe for use in stormwater drainage applications in Hervey Bay until such time as its suitability for use in subdivisional and road works has been verified.

Certification by Standards Australia with "recommended product" status, and/or its substantiation for use under the particular trench, traffic and construction loading applicable, by the Department of Main Roads could contribute significantly to allaying these concerns.

As the previous correspondence is now a little dated, which is not your company's fault, could you advise if any of these conditions have now been met?

Should you have any further queries, please contact me on 4125 9740.

Yours faithfully

NEVILLE LAVEY
PRINCIPAL ENGINEER DRAINAGE ASSETS

77 Tavistock St
Torquay
Hervey Bay

Telephone: 07 4197 4444
Facsimile: 07 4197 4455